

M-CON-KEY-p: Module for integrating access control systems

Document number: PO-211-EN Version: 1.4.0 Date of publication: May 29, 2024



Technical data

Supply voltage
11 – 16V DC

Current consumption
20mA

Number of OC outputs
4

Technical data cont.

Maximum current of a single OC output
1A

Maximum total current of all OC outputs
4A

Maximum switched load voltage
24V

Dimensions

Width
41mm

Height
44mm

Depth
16.5mm

Environment

Temperature
-40 – 50°C

Humidity
≤95%RH, non-condensing

The image above is for illustration purpose only. The actual module may vary from the one presented here.

General features

Module M-CON-KEY-p is a component of the Ampio system. Required voltage to power the module is 11 – 16V DC. The module is controlled via CAN bus.

The module has four OC binary outputs.

Typical application

- Integration of access control modules via the Wiegand bus;
- Integration of access control modules via RS-485 bus.

The M-CON-KEY-p module can only communicate with one access control module at a time. At the configuration stage, choose whether this will be a Wiegand or RS-485 bus.

List of access control modules supported by the M-CON-KEY-p module:

- Dahua DHI-ASR2201D-B
- Dahua ASR2101A

Installation

The dimensions of the module enable its installation in a standard junction box. In order to start the module, it must be connected to the CAN bus. The bus of the Ampio system consists of four wires - two for power and two for communication between the modules.

Apart from the CAN bus connector, the device has three connectors with screw terminals. In addition to integration with access control modules, they allow four resistive loads to be connected to the two-state *open-collector* outputs.

When using the open-collector outputs functionality, it should be borne in mind that the supply circuits of the connected loads are closed by the mass of the module. Therefore, it should be ensured that the mass of the device is connected to the mass of the power supply with a cable of appropriate thickness.

Device status LEDs

On the front of the module there are signalling LED indicators. The red LED with the label *CAN* indicates the status of communication on the CAN bus:

- one regular flash every 1 sec. – CAN bus communication is working properly,
- two regular flashes every 1 sec. – the module is not receiving information from other modules,
- three regular flashes every 1 sec. – the module cannot send information to the CAN bus;

Tamper contact

The module is equipped with a tamper contact so that when the appropriate logic is connected and programmed into the module, an attempt to steal the access control module can be detected.

Programming

The module is programmed with the use of the [Ampio Designer](#) software. It allows you to modify the parameters of the module and define its behaviour in response to signals directly available to the module as well as general information coming from all devices present in the home automation bus.


Default output connection

If the module has a buzzer or PIN_OK contact, it is connected to output number 2 by default, while the electric door strike is connected to output number 1 by default.

Module dimensions

Dimensions expressed in millimeters.

The dashed lines mark the areas where the device connectors or its other elements can be located.



Connection diagram

